

IKATES, s.r.o. – Laboratory for glass and building products testing



Tolstého 186, 415 03 Teplice, Czech Republic
tel. : +420 417 503 093, tel./fax: +420 417 502 825
e-mail: ikates@volny.cz, <http://go.to/ikates>

Summary report No. A-185-4AS /2007 Date: 2008-03-03

**Insulating glass units – Evaluation of the gas leakage rate
and gas concentration measured according to EN 1279-3**

For details, see the test report A-185-4A/2007

Client: eco instruments Sp. z o.o.
ul. Powsińska 18, 02-920 Warszawa, Poland

Producer : FAKRO Sp. z o.o.
ul. Węgierska 144a, Nowy Sącz, Poland

Product name: insulating glass units, trade name SET ECO

Applied gas:

Unit number:

Measured concentration c_{Ar} (%):


Nominal concentration $c_{Ar,0}$ (%)

Gas leakage rate L_{Ar} (% \cdot a $^{-1}$)

argon	
1	2
94,3	95,1
90	90
0,42	0,42

System conforms

YES	NO
-----	----


Jiří Stránský
manager of testing laboratory

